

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

PULSAR PROCESS MEASUREMENT LTD.
Cardinal Building, Sandy's Road, Malvern
WR14 1JJ Worcestershire, UK

the Certificate No: **Z01356** for the PROFIBUS device:

Model Name: **Pulsar PROFIBUS**
Revision: **1.1; SW/FW: COMMS_PRO Ver. 1.1;**
HW: COMMS_PRO Rev. 2
GSD: **PULS0B9E.gsd, File Version: 1.1**

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> DP-V0	MS0, Sync, Freeze, Fail_Safe, Set_Slave_Add
<input checked="" type="checkbox"/> DP-V1	MS1, MS2, I&M
<input checked="" type="checkbox"/> Physical Layer	RS485

Test Report Number: **PCN114-DPS-01**
Authorized Test Laboratory: **PROCENTEC, Wateringen, The Netherlands**

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 3.0 from November 2005".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by June 29, 2014 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Jörg Freitag)



(K.-P. Lindner)

