

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**Pulsar Process Measurement Ltd
Enigma Commercial Centre, Sandy's Road
WR14 1JJ Malvern, Worcestershire, UK**

the Certificate No: **Z01764** for the PROFIBUS Device:

**Model Name: Pulsar PROFIBUS PA
Revision: 1.0; SW/FW: 1.0; HW: Issue 2
GSD: PA139700.GSD, File Version: April 01, 2009**

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> DP-V0	MS0, Set_Slave_Add
<input checked="" type="checkbox"/> DP-V1	MS2, I&M
<input checked="" type="checkbox"/> Profile	PROFIBUS PA 3.02
<input checked="" type="checkbox"/> Physical Layer	MBP

Test Report Number: **PCN169-PAS-01**

Authorized Test Laboratory: **PROCENTEC, Wateringen, The Netherlands**

The tests were executed in accordance with the following documents:

“Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008” and
“Test Specifications for PA Devices, Technical specification for PROFIBUS, Version 5.0.4, February 2010”.

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by March 03, 2016 the certificate is valid for life.


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)



(K.-P. Lindner)